



Gerät / Device		Integration Revision	Anzeige- und Bedienkomponente (ABK) / Indicating and operating modules									
Model Index	Firmware K ¹ / R ²	FF Device Rev	TROVIS VIEW	DTM (FDT 1.2)	DD -> Field Communicator 375/475	Emerson DeltaV	National Instruments Fieldbus Configurator	Yokogawa Centum CS 3000	Honeywell Experion PKS	Endress+ Hauser Control Care	ABB Industrial IT	Foxboro I/A Series
00	K 1.00 R 1.00	1					≥ 2.3 ¹⁴		✓ ¹⁴			
00	K 1.11 R 1.31	1				≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴		✓ ¹⁴			✓ ¹⁴
00	K 1.21 R 1.41	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
00	K 1.22 R 1.41	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
01	K 1.23 R 1.44	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
01	K 1.24 R 1.44	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
01	K 1.25 R 1.45	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
01	K 1.25 R 1.46	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
01	K 1.26 R 1.46	1	≥ 3.20	≥1.0.0	✓	≥ 6.1 ^{14,15}	≥ 2.3 ¹⁴	✓ ^{14,15}	✓ ¹⁴	✓ ¹⁴	✓ ^{14,15}	✓ ¹⁴
01	K 2.00 R 1.52	2	≥ 3.20		✓	≥ 6.1 ^{6,14}	≥ 2.3 ^{6,14}	✓ ^{6,14}	✓ ¹⁴	✓ ¹⁴	✓ ¹⁴	✓ ¹⁴
01	K 2.01 R 1.52	2	≥ 3.20		✓	≥ 6.1 ^{6,14}	≥ 2.3 ^{6,14}	✓ ^{6,14}	✓ ¹⁴	✓ ¹⁴	✓ ¹⁴	✓ ¹⁴

¹ Firmware Kommunikation

² Firmware Regelung

⁶ mit Enhanced EDD

¹⁴ Device Description verfügbar über <http://www.samson.de/>

¹⁵ Basic Device