

Elektropneumatic Positioner Type 3730-4

Device			Indicating and operating modules							
Model Index	Firmware K ¹ / R ²	Device Rev	PA Profile	TROVIS-VIEW	Siemens PDM ³	DTM (FDT 1.2)				
00	K 1.00 – 1.10 R 1.43 – 1.44	1	3.01	≥ 3.22	≥ 5.1 ≥ 6.0 ⁴	≥ 1.3.0				
01	K 1.11 – 1.18 R 1.45 – 1.46	2	3.01	≥ 3.40	≥ 5.1 ≥ 6.0 ^{4,5}	≥ 1.3.0				
01	K2.00 R1.52	2	3.02 ⁶	≥ 4.00	≥ 6.0 ⁴	≥ 1.3.0				
01	K2.01 R1.52	2	3.02 ⁶	≥ 4.00	≥ 6.0 ⁴	≥ 1.3.0				
01	K2.02 R1.53	2	3.02 ⁶	≥ 4.00	≥ 6.0 ⁴	≥ 1.3.0				

1 Communication firmware

2 Control firmware

3 Device is subsequently added to PDM using the "device install"/"manage device catalog" function (available at <http://www.samson.de>)

4 With enhanced DD (EDD)

5 K1.11 DD revision 2 and higher

6 Certified according to 3.01. Contains all features specified for 3.02